



**DEPARTMENT OF FORESTRY AND FIRE PROTECTION**  
**OFFICE OF THE STATE FIRE MARSHAL**  
Fire and Life Safety Division - South  
602 E Huntington Dr, Suite A, Monrovia, CA 91016  
(626) 305-1908

## PRIORITY INSPECTION REPORT

### BUILDING INFORMATION

**SFM FILE NUMBER:** 52-14-21-0003-10001

**JURISDICTION:** Life Safety South

**BUILDING OWNER:**

**BUILDING NAME:** Office

**BUILDING ADDRESS:** 2001 Sugar Loaf Road, Big Pine, CA 93513

### INSPECTION INFORMATION

**Inspection Number :** 164216

**Inspection Type:** Annual

**Inspection Date :** 06/28/2024

**Inspection Status :** Failed

**Inspector:** Gavin Whims

**Inspection Hours :** 0.25

**Inspector Signature:**

**Travel Hours :** 2

**Inspection Comments:** On this date, June 27, 2024 a fire life safety inspection was conducted at Palisades Glacier High School located at 2001 Sugar Loaf Road, Big Pine, by Deputy State Fire Marshal Gavin Whims ( gavin.whims@fire.ca.gov 626-590-1249) and accompanied by on-site staff.

During the inspection the following deficiencies were documented and require corrective action. Any questions please contact the deputy listed above.

**Accompanied By:** Katie Kolker

**Title:** Superintendent

**Discussed With:** Katie Kolker

**Title:** Superintendent

**Accompanied By:**

**Signed:**

**COMMENTS OR QUESTIONS ABOUT INSPECTION SERVICES**  
Please contact CAL Fire Life Safety South at (626) 305-1908 for assistance.



**DEPARTMENT OF FORESTRY AND FIRE PROTECTION**  
**OFFICE OF THE STATE FIRE MARSHAL**  
Fire and Life Safety Division - South  
602 E Huntington Dr, Suite A, Monrovia, CA 91016  
(626) 305-1908

## PRIORITY INSPECTION REPORT

**Violation # 777171**

**Description:** Maintenance of Equipment

**Violation Code:** Title 19 Title 19 Current-3.24

**Comments:** All fire alarm systems, fire detection systems, automatic sprinkler or extinguishing systems, communication systems, and all other equipment, material or systems required by these regulations shall be maintained in an operable condition at all times. Upon disruption or diminishment of the fire protective qualities of such equipment, material or systems, immediate action shall be instituted to effect a reestablishment of such equipment material or systems to their original normal and operational condition.

It was documented that the fire alarm panel was non-operational at the time of inspection, provide maintenance to the fire alarm system



**Comments:**

**COMMENTS OR QUESTIONS ABOUT INSPECTION SERVICES**  
Please contact CAL Fire Life Safety South at (626) 305-1908 for assistance.



**DEPARTMENT OF FORESTRY AND FIRE PROTECTION**  
**OFFICE OF THE STATE FIRE MARSHAL**  
Fire and Life Safety Division - South  
602 E Huntington Dr, Suite A, Monrovia, CA 91016  
(626) 305-1908

## **PRIORITY INSPECTION REPORT**

### **Violation # 777172**

**Description:** Inspection, testing and maintenance

**Violation Code:** Title 24 CFC 2022-907.8.4

**Comments:** The building owner shall be responsible to maintain the fire and life safety systems in an operable condition at all times. Service personnel shall meet the qualification requirements of NFPA 72 for inspection, testing and maintenance of such systems. Records of inspection, testing and maintenance shall be maintained.

**Comments:**

### **Violation # 777173**

**Description:** Testing

**Violation Code:** Title 24 CFC 2022-907.8.2

**Comments:** Testing shall be performed in accordance with the schedules in NFPA72 or more frequently where required by the fire code official. Records of testing shall be maintained.

Provide annual testing and maintenance to the fire alarm system, once completed send over the documentation for review.

**Comments:**

**COMMENTS OR QUESTIONS ABOUT INSPECTION SERVICES**  
Please contact CAL Fire Life Safety South at (626) 305-1908 for assistance.



**DEPARTMENT OF FORESTRY AND FIRE PROTECTION**  
**OFFICE OF THE STATE FIRE MARSHAL**  
Fire and Life Safety Division - South  
602 E Huntington Dr, Suite A, Monrovia, CA 91016  
(626) 305-1908

## PRIORITY INSPECTION REPORT

### Violation # 777175

**Description:** Group E schools.

**Violation Code:** Title 24 CFC 2022-907.6.6.4

**Comments:** Automatic fire alarm systems shall be monitored and shall transmit the alarm, supervisory and trouble signals to an approved supervising station in accordance with NFPA 72. The supervising station shall be listed as either UUFX (Central Station) or UUJS (remote & proprietary) by the Underwriters Laboratory Inc. (UL) or other approved listing and testing laboratory or shall comply with the requirements of FM 3011. Termination of monitoring services shall be in accordance with Section 907.6.6.2

Fire alarm system shall be contacted to a supervisory system, once completed and established provide documentation of connection.

**Comments:**

**COMMENTS OR QUESTIONS ABOUT INSPECTION SERVICES**  
Please contact CAL Fire Life Safety South at (626) 305-1908 for assistance.