



DEPARTMENT OF FORESTRY AND FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
Fire and Life Safety Division - South
602 E Huntington Dr, Suite A, Monrovia, CA 91016
(626) 305-1908

PRIORITY INSPECTION REPORT

BUILDING INFORMATION

SFM FILE NUMBER: 52-14-21-0008-10001

JURISDICTION: Life Safety South

BUILDING OWNER:

BUILDING NAME: After School Building

BUILDING ADDRESS: 500 S Main Street, Big Pine, CA 93513

INSPECTION INFORMATION

Inspection Number : 147299

Inspection Type: Annual

Inspection Date : 08/29/2023

Inspection Status : Failed

Inspector: Gavin Whims

Inspection Hours : 0.5

Inspector Signature:

Travel Hours : 0

Inspection Comments: On this date, August 29, 2023 an inspection was conducted Big Pine Unified School District 500 South Main Street Big Pine by Deputy State Fire Marshal Gavin Whims (gavin.whims@fire.ca.gov 626-590-1249) and accompanied by on-siter staff.

The following violations were documented and require immediate corrective action.

Accompanied By: Ed Dardenne-Ankringa

Title: Principle

Discussed With: Ed Dardenne-Ankringa

Title: Principle

Accompanied By:

Signed:

COMMENTS OR QUESTIONS ABOUT INSPECTION SERVICES
Please contact CAL Fire Life Safety South at (626) 305-1908 for assistance.



DEPARTMENT OF FORESTRY AND FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
Fire and Life Safety Division - South
602 E Huntington Dr, Suite A, Monrovia, CA 91016
(626) 305-1908

PRIORITY INSPECTION REPORT

Violation # 655077

Description: Open Electrical Terminations.

Violation Code: Title 24 CFC 2022-603.2.2

Comments: Open junction boxes and open-wiring splices shall be prohibited. Approved covers shall be provided for all switch and electrical outlet boxes.

Cover all open junction boxes.



Comments:

COMMENTS OR QUESTIONS ABOUT INSPECTION SERVICES
Please contact CAL Fire Life Safety South at (626) 305-1908 for assistance.