



DEPARTMENT OF FORESTRY AND FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
Fire and Life Safety Division - South
602 E Huntington Dr, Suite A, Monrovia, CA 91016
(626) 305-1908

PRIORITY INSPECTION REPORT

BUILDING INFORMATION

SFM FILE NUMBER: 52-14-21-0015-10001

JURISDICTION: Life Safety South

BUILDING OWNER:

BUILDING NAME: Boardroom

BUILDING ADDRESS: 500 S Main Street, Big Pine, CA 93513

INSPECTION INFORMATION

Inspection Number : 147306

Inspection Type: Annual

Inspection Date : 08/29/2023

Inspection Status : Failed

Inspector: Gavin Whims

Inspection Hours : 0

Inspector Signature: 

Travel Hours : 0

Inspection Comments: On this date, August 29, 2023 an inspection was conducted Big Pine Unified School District 500 South Main Street Big Pine by Deputy State Fire Marshal Gavin Whims (gavin.whims@fire.ca.gov 626-590-1249) and accompanied by on-siter staff.

Was unable to inspect the building, all comment from 2022 inspection remain, Spot inspection 120612.

Accompanied By:

Signed:

COMMENTS OR QUESTIONS ABOUT INSPECTION SERVICES
Please contact CAL Fire Life Safety South at (626) 305-1908 for assistance.



DEPARTMENT OF FORESTRY AND FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
Fire and Life Safety Division - South
602 E Huntington Dr, Suite A, Monrovia, CA 91016
(626) 305-1908

PRIORITY INSPECTION REPORT

Violation # 655090

Description:

Violation Code: NFPA 72 2016-10.6.10.1.2

Comments: Where the battery is not marked with the month/year by the manufacturer, the installer shall obtain the date code and mark the battery with the month/year of battery manufacture.

Fire alarm batteries shall be properly marked.

Comment remains

Accompanied By: Ed Dardenne-Ankringa

Title: Principle

Discussed With: Ed Dardenne-Ankringa

Title: Principle

Comments:

COMMENTS OR QUESTIONS ABOUT INSPECTION SERVICES
Please contact CAL Fire Life Safety South at (626) 305-1908 for assistance.



DEPARTMENT OF FORESTRY AND FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
Fire and Life Safety Division - South
602 E Huntington Dr, Suite A, Monrovia, CA 91016
(626) 305-1908

PRIORITY INSPECTION REPORT

Violation # 655093

Description: Maintenance.

Violation Code: Title 19 Title 19 Current-1.14

Comments: Every fire alarm system or device, sprinkler system, fire extinguisher, fire hose. fire-resistive assembly or any other fire safety assembly. device. material or equipment installed and retained in service in any building or structure subject to California Code of Regulations, Title 19, Division I regulations shall be maintained in an operable condition at all times in accordance with California Code of Regulations. Title 19, Division I regulations and with their intended use.

Provide annual service to the fire alarm system including the fire smoke dampers from a state licensed contractor and provide the annual fire alarm report to the field deputy for review

Accompanied By: Ed Dardenne-Ankringa

Title: Principle

Discussed With: Ed Dardenne-Ankringa

Title: Principle

Comments:

COMMENTS OR QUESTIONS ABOUT INSPECTION SERVICES
Please contact CAL Fire Life Safety South at (626) 305-1908 for assistance.



DEPARTMENT OF FORESTRY AND FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
Fire and Life Safety Division - South
602 E Huntington Dr, Suite A, Monrovia, CA 91016
(626) 305-1908

PRIORITY INSPECTION REPORT

Violation # 655091

Description: Circuit Breaker Lock.

Violation Code: NFPA 72 2016-10.6.5.4

Comments: Where a circuit breaker is, an approved breaker locking device shall be installed.

Comment remains

Accompanied By: Ed Dardenne-Ankringa

Title: Principle

Discussed With: Ed Dardenne-Ankringa

Title: Principle

Comments:

COMMENTS OR QUESTIONS ABOUT INSPECTION SERVICES
Please contact CAL Fire Life Safety South at (626) 305-1908 for assistance.



DEPARTMENT OF FORESTRY AND FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
Fire and Life Safety Division - South
602 E Huntington Dr, Suite A, Monrovia, CA 91016
(626) 305-1908

PRIORITY INSPECTION REPORT

Violation # 655092

Description:

Violation Code: NFPA 72 2016-10.6.5.2.3

Comments: For fire alarm and/or signaling systems, the circuit disconnecting means shall have a red marking

Accompanied By: Ed Dardenne-Ankringa

Title: Principle

Discussed With: Ed Dardenne-Ankringa

Title: Principle

Comments:

COMMENTS OR QUESTIONS ABOUT INSPECTION SERVICES
Please contact CAL Fire Life Safety South at (626) 305-1908 for assistance.