



DEPARTMENT OF FORESTRY AND FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
Fire and Life Safety Division - South
602 E Huntington Dr, Suite A, Monrovia, CA 91016
(626) 305-1908

PRIORITY INSPECTION REPORT

BUILDING INFORMATION

SFM FILE NUMBER: 52-14-01-0015-10001

JURISDICTION: Life Safety South

BUILDING OWNER:

BUILDING NAME: BPUSD Conference Bdg.

BUILDING ADDRESS: 500 S Main Street, Big Pine, CA 93513

INSPECTION INFORMATION

Inspection Number : 163976

Inspection Type: Annual

Inspection Date : 06/25/2024

Inspection Status : Failed

Inspector: Gavin Whims

Inspection Hours : 0.25

Inspector Signature:

Travel Hours : 1

Inspection Comments: On this date, June 25, 2024 a fire life safety inspection was conducted by Deputy State Fire Marshal Gavin Whims (gavin.whims@fire.ca.gov 626-590-1249) and accompanied by on-site staff.

During the inspection the following deficiencies were documented and require corrective action. Any questions please contact the deputy listed above.

Accompanied By: Ed Dardenne-Ankringa

Title: Superintendent & Principal

Discussed With: Ed Dardenne-Ankringa

Title: Superintendent & Principal

Accompanied By:

Signed:

COMMENTS OR QUESTIONS ABOUT INSPECTION SERVICES
Please contact CAL Fire Life Safety South at (626) 305-1908 for assistance.



DEPARTMENT OF FORESTRY AND FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
Fire and Life Safety Division - South
602 E Huntington Dr, Suite A, Monrovia, CA 91016
(626) 305-1908

PRIORITY INSPECTION REPORT

Violation # 776034

Description: Circuit Breaker Lock.

Violation Code: NFPA 72 2016-10.6.5.4

Comments: Where a circuit breaker is, an approved breaker locking device shall be installed.

Provide a breaker lock for the fire alarm breaker

Comments:

COMMENTS OR QUESTIONS ABOUT INSPECTION SERVICES
Please contact CAL Fire Life Safety South at (626) 305-1908 for assistance.